



# **PICS EE650D & EE660D**

## **BACnet Protocol Implementation Conformance Statement**

*YOUR PARTNER IN SENSOR TECHNOLOGY*



**ELEKTRONIK®**  
Ges.m.b.H.

# Content

<b>1. GENERAL INFORMATION .....</b>	<b>3</b>
<b>2. BACNET STANDARDIZED DEVICE PROFILE (ANNEX L).....</b>	<b>3</b>
<b>3. LIST OF ALL SUPPORTED BACNET INTEROPERABILITY BUILDING BLOCKS (ANNEX K): .....</b>	<b>3</b>
<b>4. SEGMENTATION CAPABILITY:.....</b>	<b>3</b>
<b>5. BACNET STANDARD OBJECT TYPES SUPPORTED .....</b>	<b>3</b>
<b>6. DATA LINK LAYER OPTIONS.....</b>	<b>4</b>
<b>7. DEVICE ADDRESS BINDING.....</b>	<b>4</b>
<b>8. NETWORKING OPTIONS .....</b>	<b>4</b>
<b>9. NETWORK SECURITY OPTIONS .....</b>	<b>4</b>
<b>10. CHARACTER SETS SUPPORTED .....</b>	<b>4</b>
<b>11. BACNET OBJECTS.....</b>	<b>5</b>
11.1 <i>Device Object</i> .....	5
11.2 <i>Analog Input Objects</i> .....	6
<b>12. MISCELLANEOUS INFORMATION .....</b>	<b>7</b>

# 1. GENERAL INFORMATION

**Date:** 04.07.2018  
**Vendor Name:** E+E Elektronik  
**Product Name:** EE650D or EE660D  
**Product Model Number:** EE650D or EE660D

These are the generic denominations for EE650 or EE660 devices with digital output (RS485) and BACnet MS/TP protocol. For type number of specific EE650D or EE660D devices see the respective data sheets at:  
[www.epluse.com/fileadmin/data/product/ee650/datasheet\\_EE650.pdf](http://www.epluse.com/fileadmin/data/product/ee650/datasheet_EE650.pdf)  
[www.epluse.com/fileadmin/data/product/ee660/datasheet\\_EE660.pdf](http://www.epluse.com/fileadmin/data/product/ee660/datasheet_EE660.pdf)

**Application Software Version:** 1.0  
**Firmware Revision:** 1.0  
**BACnet Protocol Version:** 1  
**BACnet Protocol Revision:** 10

## Product Description:

Air velocity BACnet MS/TP Smart Sensor Master device EE650D ("high flow type", 0-20m/s) or EE660D ("low flow type", 0-2m/s, derived from EE650D).

# 2. BACNET STANDARDIZED DEVICE PROFILE (ANNEX L)

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

# 3. LIST OF ALL SUPPORTED BACNET INTEROPERABILITY BUILDING BLOCKS (ANNEX K):

DS-RP-B..... Data Sharing – Read Property – B  
DS-RPM-B..... Data Sharing – Read Property Multiple – B  
DS-WP-B..... Data Sharing – Write Property – B  
DM-DDB-B ..... Data Management – Dynamic Device Binding – B  
DM-DOB-B ..... Data Management – Dynamic Object Binding – B  
DM-DCC-B ..... Data Management – Device Communication Control – B  
DM-RD-B..... Data Management – Reinitialize Device – B

# 4. SEGMENTATION CAPABILITY:

- Able to transmit segmented messages
- Able to receive segmented messages

# 5. BACNET STANDARD OBJECT TYPES SUPPORTED

- |  |  |   |
|--|--|---|
| <input type="checkbox"/> Accumulator             | <input type="checkbox"/> Command           | <input type="checkbox"/> Multistate Output  |
| <input checked="" type="checkbox"/> Analog Input | <input checked="" type="checkbox"/> Device | <input type="checkbox"/> Multistate Value   |
| <input type="checkbox"/> Analog Output           | <input type="checkbox"/> Event Enrollment  | <input type="checkbox"/> Notification Class |
| <input type="checkbox"/> Analog Value            | <input type="checkbox"/> File              | <input type="checkbox"/> Program            |
| <input type="checkbox"/> Averaging               | <input type="checkbox"/> Group             | <input type="checkbox"/> Pulse Converter    |
| <input type="checkbox"/> Binary Input            | <input type="checkbox"/> Life Safety Point | <input type="checkbox"/> Schedule           |
| <input type="checkbox"/> Binary Output           | <input type="checkbox"/> Life Safety Zone  | <input type="checkbox"/> Trend Log          |
| <input type="checkbox"/> Binary Value            | <input type="checkbox"/> Loop              |   |
| <input type="checkbox"/> Calendar                | <input type="checkbox"/> Multistate Input  |   |

## 6. DATA LINK LAYER OPTIONS

- BACnet IP, (Annex J):
- BACnet IP, (Annex J), Foreign Device:
- ISO 8802-3, Ethernet (Clause 7):
- ATA 878.1, 2.5 Mb. ARCNET (Clause 8):
- ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s):
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 57600, 76800, 115200
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- BACnet/Zigbee (Annex O):
- Other:

## 7. DEVICE ADDRESS BINDING

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)  Yes  No

## 8. NETWORKING OPTIONS

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
  - Does the BBMD support registrations by Foreign Devices?  Yes  No
  - Does the BBMD support network address translation?  Yes  No

## 9. NETWORK SECURITY OPTIONS

- Non-secure Device - is capable of operating without BACnet Network Security
- Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
  - Multiple Application-Specific Keys
  - Supports encryption (NS-ED BIBB)
  - Key Server (NS-KS BIBB)

## 10. CHARACTER SETS SUPPORTED

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ISO 10646 (UTF-8)  IBM™ /Microsoft™ DBCS  ISO 8859-1
- ISO 10646 (UCS-2)  SO 10646 (UCS-4)  JIS X 0208

# 11. BACNET OBJECTS

This part describes the various BACnet objects in detail (initial values for EE660D in brackets). In the following sections the main properties of the individual objects are explained.

## 11.1 Device Object

Property	Data Type	Initial Value	R/O/P	Persistence
Object Identifier	BACnetObjectIdentifier	Unique Object Instance (0 – 4194302)	R (W)	Non Volatile
Object Name	CharacterString[15]	“EE650D_XXXXXXXX” or “EE660D_XXXXXXXX” (X ... Unique characters)	R (W)	Non Volatile
Object Type	BACnetObjectType (Enum.)	OBJECT_DEVICE	R (R)	Fixed
Description	CharacterString[15]	“EE650D” (“EE660D”)	O (W)	Non Volatile
System Status	BACnetDeviceStatus (Enum.)	STATUS_OPERATIONAL	R (R)	Volatile
Vendor Name	CharacterString	“E+E Elektronik”	R (R)	Fixed
Vendor Identifier	Unsigned16	623	R (R)	Fixed
Model Name	CharacterString	“EE650D” (“EE660D”)	R (R)	Fixed
Firmware Revision	CharacterString	“1.0”	R (R)	Fixed
Application Software Version	CharacterString	“1.0”	R (R)	Fixed
Location	CharacterString[15]	“AUT”	O (W)	Non Volatile
Protocol Version	Unsigned	1	R (R)	Fixed
Protocol Revision	Unsigned	10	R (R)	Fixed
Protocol Services Supported	BACnetProtocolServices Supported (Bit-String)	Read Property Read Property Multiple Write Property Device Comm. Control Reinitialize Device Who-Is Who-Has	R (R)	Fixed
Protocol Object Types Supported	BACnetObjectTypes Supported (Bit-String)	Device Analog Input	R (R)	Fixed
Object List	BACnetARRAY[N] of BACnetObjectIdentifier	EE650D and EE660D: Device Object AI0 (Temperature) AI1 (Air velocity)	R (R)	Fixed
Max APDU Length Accepted	Unsigned16	480	R (R)	Fixed
Segmentation Supported	BACnetSegmentation (Enum.)	NO_SEGMENTATION	R (R)	Fixed
APDU Timeout	Unsigned	3000	R (R)	Fixed
Number of APDU Retries	Unsigned	3	R (R)	Fixed
Device Address Binding	List of BACnetAddressBinding	NULL	R (R)	Fixed
Database Revision	Unsigned	0	R (W)	Non Volatile
Max Info Frames	Unsigned	1	O (R)	Fixed
Max Master	Unsigned	127	O (W)	Non Volatile
Communication Parameter	CharacterString	“9600-8n1”	P (W)	Non Volatile

- R (R)..... Required Property (Readable)
- R (W)..... Required Property (Read-/Writable)
- O (R)..... Optional Property (Readable)
- O (W)..... Optional Property (Read-/Writable)
- P (R)..... Proprietary Property (Readable)
- P (W)..... Proprietary Property (Read-/Writable)

**Max Master:**

The maximum “Max Master” Property is 127. This value is writable via BACnet write property.

### Communication Parameter:

For changing the RS485 communication parameters it is relevant to observe the character string format. The character string consists of following parts:

1. Baud rate (9600, 19200, 38400, 57600, 76800, 115200)
2. “\_”
3. Number of data bits (fixed: 8)
4. Parity (fixed: no)
5. Number of stop bits (fixed: 1)

### Example:

- Change parameters to: Baud = 38400, 8 data bits, no parity, 1 stop bit:  
String: “38400-8n1”

**ATTENTION:** The character string shall end with the terminating 0.

## 11.2 Analog Input Objects

Each analog input object has the same structure. It is the same for both EE650D and EE660D.

Property	Data Type	Initial Value	R/O/P	Persistence
Object Identifier	BACnetObjectIdentifier	0 ... Temperature 1 ... Air velocity	R	Fixed
Object Name	CharacterString	“T” ... Temperature “V” ... Air velocity	R	Fixed
Description	CharacterString	(see below)	O	Fixed
Object Type	BACnetObjectType (Enum.)	OBJECT_ANALOG_INPUT	R	Fixed
Present Value	Real	0.0	R (W) <sup>a.)</sup>	Volatile
Status Flags	BACnetStatusFlags (Bit-String)	false, false, false, false	R	Volatile
Event State	BACnetEventState	NORMAL	R	Volatile
Out of Service	Boolean	false	R (W)	Volatile
Units	BACnetEngineeringUnits (Enum.)	(see below)	R (W)	Non Volatile
Reliability	BACnetReliability (Enum.)	NO_FAULT_DETECTED	R (W) <sup>a.)</sup>	Volatile

a.) When “Out of Service” flag is true, value is writable.

### Description Property:

The following table shows the possible object descriptions depending on the selected units:

Initial Value	Alternative 1
“Temperature [deg. C]”	“Temperature [deg. F]”
“Air velocity [m/s]”	“Air velocity [ft/min]”

### Present Value Property:

This property represents the actual sensor or actual calculation value. When the “Out of Service” flag is true, this value is writable. The default values when “Out of Service” is set are 50.0.

**Status Flags Property:**

The following table describes the possible states of the “Status Flags” property:

Flag	State	Reason
IN_ALARM	false	Value of “Event State” property is NORMAL (0)
	true	Value of “Event State” property is not NORMAL (0)
FAULT	false	Value of “Reliability” property is NO_FAULT_DETECTED
	true	Value of “Reliability” property is not NO_FAULT_DETECTED
OVERRIDDEN	false	Always false
OUT_OF_SERVICE	false	“Present Value” and “Reliability” properties are not writeable via BACnet
	true	“Present Value” and “Reliability” properties are writeable via BACnet

**Event State:**

The following table describes the possible states of the “Event State” property:

State	Reason
NORMAL (0)	Value of “Reliability” property is NO_FAULT_DETECTED
FAULT (1)	Value of “Reliability” property is not NO_FAULT_DETECTED

**Units:**

The following table lists the possible units for each analog input object:

Initial Value	Alternative 1
Degrees Celsius (62)	Degrees Fahrenheit (64)
Velocity Meter per Second (74)	Velocity Feet per Minute (77)

**Reliability:**

The following table describes the possible states of the “Reliability” property:

State	Reason
NO_FAULT_DETECTED (0)	No fault detected
NO_SENSOR (1)	Sensor is damaged or not connected

## 12. MISCELLANEOUS INFORMATION

**Reinitialize Device (RD):**

The RD function is used to restart/ reboot the entire transmitter via BACnet. To use reinitialize device functionality a password is needed. The password is: “BACnet123”.

**Device Communication Control (DCC):**

The DCC functionality is used to stop initiating messages on the BACnet network. After receiving a DCC stop initiate message, the device does not response to a request any more, except to RD or DCC requests. The use of the device communication control functionality is password protected. The password is: “BACnet123”.



#### HEADQUARTERS

##### **E+E Elektronik Ges.m.b.H.**

Langwiesen 7  
A-4209 Engerwitzdorf  
Austria  
Tel: +43 7235 605 0  
Fax: +43 7235 605 8  
info@epluse.com  
www.epluse.com

#### SUBSIDIARIES

##### **E+E Elektronik Germany**

info@epluse.de

Office Bad Homburg  
Tel: +49 6172 13881-0

Office Hamburg  
Tel: +49 160 9050 6460

Office Stuttgart  
Tel: +49 151 538 37 500

##### **E+E Elektronik Italy**

info@epluse.it  
Tel: +39 02 2707 86 36

##### **E+E Elektronik France**

info@epluse.fr  
Tel: +33 4 74 72 35 82

##### **E+E Elektronik USA**

office@epluse.com  
Office Boston  
Tel: +1 847 490 0520

Office Chicago  
Tel: +1 847 490 0520

##### **E+E Elektronik Korea**

Tel: +82 31 732 6050  
info@epluse.co.kr

##### **E+E Elektronik China**

info@epluse.cn  
Office Beijing  
Tel: +86 10 8499 2361

Office Shanghai  
Tel: +86 21 6117 6129

Office Guangzhou  
Tel: +86 20 3898 7052

YOUR PARTNER IN SENSOR TECHNOLOGY



**ELEKTRONIK®**  
Ges.m.b.H.